

The Town of New Canaan, Connecticut

Department of Public Works

ADVERTISEMENT FOR BIDS

The Public Works Department of the Town of New Canaan, Connecticut, will receive sealed bids for a KSB model KRT K 100-251/164XG submersible non-clog, pump with 20 HP, 460/3/60 VAC, 1750 RPM motor until 10:00AM Local Time on December 6th, 2017 at the Department of Public Works Office, located at the Town of New Canaan Town Hall 77 Main Street, New Canaan, CT 06840, at which time and place all bids will be publicly opened and read aloud.

Specification documents are available at the Town of New Canaan Wastewater Plant, 394 Main Street, New Canaan, Connecticut 06840 or by calling Jim Rogers, Facilities Superintendent at 203-594-3700. Specifications may also be obtained by e-mailing to [james.rogers@newcanaanct.gov](mailto:james.rogers@newcanaanct.gov).

The Owner may waive any informalities or minor defects, or reject any or all bids if it is in the best interest of the Town of New Canaan to do so.

Jim Rogers  
Superintendent, Town of New Canaan Water  
Pollution Control Facility  
New Canaan, CT

**Town Of New Canaan Water Pollution Control Facility**

***Equipment Bid***

**BID PROPOSAL FORM**

*(Use this form, only)*

November 7, 2017

**Water Pollution Control Facility  
EQUIPMENT NOTICE AND INSTRUCTIONS TO BIDDERS**

Sealed bids will be received by the Town of New Canaan, Connecticut for the furnishing of one (1) **KSB Model KRT K 100-251 / 164XG submersible pump**, as specified, until 10:00 AM Local Time on Wednesday December 6th, 2017 at the Department of Public Works Office, located at the New Canaan Town Hall 77 Main Street New Canaan, CT 06840, at which time and place all bids received will be opened.

Results of such bids will be sent by mail to all companies upon request who showed interest. Request for bid results can be sent to james.rogers@newcanaanct.gov.

Bids must be submitted in a sealed envelope addressed to the Town of New Canaan, CT. The name and address of the bidder and the date and hour of the opening of the bid must appear on the envelope in which the proposal is submitted. Bids may be mailed to Town of New Canaan Water Pollution Control Facility 77 Main Street New Canaan, CT 06840. "Attention Submersible Pump Bid"

No bidder may withdraw his bid within 90 days after the actual date of the bid opening.

The Town of New Canaan reserves the right to reject any and all bids or any part thereof to waive defects in the same or to accept any proposal or any part thereof deemed to be in the best interest of the Town of New Canaan, Connecticut.

All bidders are requested to note that the award of this Bid is subject to the following conditions and contingencies:

- 1) The approval of such governmental agencies as may be required by law.
- 2) The appropriation of adequate funds by the proper agencies.
- 3.) All shipping and handling charges shall be included in the Bid Proposal. Delivery of the equipment is to be at the Wastewater Treatment Plant located at 394 Main Street, New Canaan, CT 06840.

**CODE OF ETHICS**

Pursuant to section 17-5.F of the Town Code of Ethics, proposers hereby certify as part of the proposal that no payment, gift or thing of value of any kind was given or promised to or received by any person holding office or employment with the Town of New Canaan for the purpose of gaining acceptance of the proposal or bringing about a contract. A false certification of the matters herein shall be deemed a material breach of any contract.

Complete specifications shall be included with all Bids. Bidder must meet all of the above requirements and all specification requirements as stated below for bid to be considered.

Bidders are requested to acknowledge receipt of this invitation to bid by facsimile (203-594-3702) or email ([james.rogers@newcanaanct.gov](mailto:james.rogers@newcanaanct.gov)) to the attention of Jim Rogers (Plant Superintendent) in order to receive any addendums that might be issued. Failure to do so will be sufficient grounds for rejection of the bid by the Town.

### EQUIPMENT ITEM

#### PART 1 GENERAL

##### DESCRIPTION

One (1) – KSB model KRT K 100-251 / 164XG submersible non-clog, pump with 20 HP, 460/3/60 VAC, 1750 RPM motor to meet the design duty point of 500 GPM @ 85' TDH. Pump is in standard KSB cast-iron construction with 4" suction / discharge; silicon carbide / silicon carbide seal faces on the pump end; carbon / silicon carbide faces on the bearing side; stainless steel impeller wear ring; cast iron stationary wear ring; motor moisture / over-temperature protection; 50' power cable; 3" solids handling; non-witnessed performance testing to HI Level "A" standards.

Submersible Pump \$ \_\_\_\_\_

Adder: Pump Guide Rail Bracket \$ \_\_\_\_\_

Total Price (Including Freight) (\$ \_\_\_\_\_)

\_\_\_\_\_  
Written Amount

Company Name \_\_\_\_\_

Address \_\_\_\_\_

\_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_

Written \_\_\_\_\_